

# Field Operation of Multiple BESSs for Demand Management of a Large-scale Customer



**Kim, Seul-Ki**

**May 18, 2017**

# Overview

**1**

**Multiple BESSs in KERI**

**2**

**Optimal Operation Framework**

**3**

**Field Operation Results**


**4**

**Observations**



# Multiple BESSs in KERI

## ◆ KERI MG



# Multiple BESSs in KERI

## ◆ Specifications


	specification	
System	Lead-acid Battery ESS 1 & 2	Lithium Polymer Battery ESS
Battery	<ul style="list-style-type: none"> <li>• Maintenance-free gel type lead-acid battery</li> <li>• capacity: 1,200kWh * 2</li> <li>• Life cycle: 2,500 cycles at DOD 70%</li> <li>• BMS (1 Banks, 60 Slaves)</li> </ul>	<ul style="list-style-type: none"> <li>• Lithium polymer battery</li> <li>• Capacity: 405kWh 101.5.kWh * 4 racks</li> <li>• Life cycles: 3,500 cycles at DOD 80%</li> <li>• BMS (1 Bank, 4 Masters, 48 Slaves)</li> </ul>
PCS	250kW *2 Units	250kW*1 Unit
EMS	Server 1 (Applications, SCADA), Server 2 (Database)	



# Operation Framework

## ◆ Time-of-Use (TOU) Pricing


- **Peak charge** based on highest 15 min. average peak of Jan., Feb., Jul., Aug., Nov., Dec., and Current Month in one recent year
- **Energy Charge** based on electricity consumption at each hour



TOU for Industrial Customer

# Operation Framework

## ◆ Operation Strategy




- Peak reduction → Peak charge saving
- Load shifting → Energy charge saving

# Operation Framework

## ◆ Control Process


- 2-level control: handling uncertainties in
  - Load forecast
  - SOC estimation
- Scheduler
- Final dispatcher



# Operation Framework

## ◆ Optimal Scheduling

- Cycle: every 1 hour
- Model predictive control
- Objective: daily energy cost minimization
- Constraints
  - Max. and Min. of BESS power
  - Max. and Min. SOC of Batteries
  - Max. and Min. load
- Modeling Consideration
  - Battery and inverter efficiency (varying)
  - State of Health → active capacity





# Operation Framework


## ◆ Optimal Scheduling

Time	Input		Lithium BESS			Lead-acid BESS 1			Lead-acid BESS 2			Mng. load [kW]	Energy charge	
	Load forecast [kW]	price [cent/kWh]	Schd. [kW]	eff. [%]	SOC [%]	Schd. [kW]	eff. [%]	SOC [%]	Schd. [kW]	eff. [%]	SOC [%]		Before [USD]	After [USD]
0:00	1,104	6.1	<b>-51</b>	95.1	24	<b>-70</b>	94.3	55	<b>-70</b>	94.3	55	1,296	67	79
1:00	1,087	6.1	<b>-50</b>	95.0	36	<b>-74</b>	94.3	61	<b>-74</b>	94.3	61	1,285	66	78
2:00	1,081	6.1	<b>-51</b>	95.1	49	<b>-74</b>	94.3	67	<b>-74</b>	94.3	67	1,280	66	78
3:00	1,160	6.1	<b>-53</b>	95.1	62	<b>-74</b>	94.3	73	<b>-74</b>	94.3	73	1,361	71	83
4:00	1,116	6.1	<b>-58</b>	95.1	76	<b>-74</b>	94.3	80	<b>-74</b>	94.3	80	1,322	68	81
5:00	1,054	6.1	<b>0</b>	91.1	76	<b>-75</b>	94.3	86	<b>-75</b>	94.3	86	1,204	64	74
6:00	1,161	6.1	<b>0</b>	91.1	76	<b>-79</b>	94.4	93	<b>-79</b>	94.4	93	1,320	71	81
7:00	1,967	6.1	<b>0</b>	91.1	76	<b>-90</b>	94.5	100	<b>-90</b>	94.5	100	2,147	120	131
8:00	3,290	6.1	<b>-97</b>	95.5	100	<b>0</b>	90.2	100	<b>0</b>	90.2	100	3,387	201	207
9:00	3,537	10.6	<b>0</b>	91.1	100	<b>0</b>	90.2	100	<b>0</b>	90.2	100	3,537	374	374
10:00	3,506	16.1	<b>58</b>	95.1	84	<b>155</b>	91.3	85	<b>155</b>	91.3	85	3,138	566	506
11:00	4,397	16.1	<b>51</b>	95.1	70	<b>155</b>	91.3	70	<b>155</b>	91.3	70	4,034	709	651
12:00	4,754	10.6	<b>-110</b>	95.5	97	<b>-60</b>	94.2	75	<b>-60</b>	94.2	75	4,984	502	527
13:00	5,228	10.6	<b>-1</b>	91.2	98	<b>-55</b>	94.1	79	<b>-55</b>	94.1	79	5,339	552	564
14:00	5,584	10.6	<b>0</b>	91.1	98	<b>-62</b>	94.2	85	<b>-62</b>	94.2	85	5,708	590	603
15:00	5,124	10.6	<b>0</b>	91.1	98	<b>-66</b>	94.2	90	<b>-66</b>	94.2	90	5,257	541	556
16:00	4,652	10.6	<b>-9</b>	91.8	100	<b>-117</b>	94.7	100	<b>-117</b>	94.7	100	4,895	492	517
17:00	3,597	16.1	<b>53</b>	95.1	86	<b>208</b>	86.8	79	<b>208</b>	86.8	79	3,129	580	505
18:00	3,267	16.1	<b>0</b>	91.1	86	<b>208</b>	86.8	58	<b>208</b>	86.8	58	2,852	527	460
19:00	2,673	16.1	<b>57</b>	95.1	70	<b>208</b>	86.8	37	<b>208</b>	86.8	37	2,201	431	355
20:00	3,684	10.6	<b>-55</b>	95.1	84	<b>-117</b>	94.7	46	<b>-117</b>	94.7	46	3,973	389	420
21:00	3,384	10.6	<b>1</b>	91.2	83	<b>-119</b>	94.6	56	<b>-119</b>	94.6	56	3,620	358	382
22:00	773	16.1	<b>250</b>	95.0	15	<b>208</b>	86.8	35	<b>208</b>	86.8	35	107	125	17
23:00	1,156	6.1	<b>0</b>	91.1	15	<b>-150</b>	92.5	47	<b>-150</b>	92.5	47	1,456	71	89
Total	-	-	-	-	-	-	-	-	-	-	-	-	7,602	7,417

# Operation Framework

## ◆ Real-time Dispatch

- Cycle: 1 second
- Uncertainty in load forecast and SOC estimation
- Prevention of violation of constraints
  - SOC and Load constraints
- Power sharing in peak-cut mode
- Real-time estimation of 15 min. average load



# Field Operation Results

## ◆ ESS Management System (EMS)



▲ Overview  
▼ Schedule

▲ Main Control  
▼ Operation result

# Field Operation Results


## ◆ EMS - scheduling



■ Lead1 ESS(kW)   
 ■ Lead2 ESS(kW)   
 ■ Li ESS(kW)   
 — Lead1 SOC(%)   
 — Lead2 SOC(%)   
 — Li SOC(%)

# Field Operation Results


## ◆ EMS - schedule vs actual operation





# Field Operation Results


## ◆ EMS - operation result






# Field Operation Results

## ◆ Actual Power vs Schedule



Peak day



Off-peak day



# Field Operation Results

## ◆ Performance Indices

- **PMI** (Peak Management Index)

= Actual peak reduction [kW] / Total sum of BESS inverters [kW]

- **OPI** (Optimal operation Performance Index)

= Actual energy cost saving [KRW] / Max. available energy cost saving\* [KRW]

\*Under peak load constraint

# Field Operation Results

## ◆ PMI Performance

Month	Original Peak [kW]	Managed Peak [kW]	Peak Reduction [kW]	PMI [%]
<b>Jul. 2015</b>	5,812	5,207	605	<b>80.7</b>
<b>Aug.</b>	6,347	5,710	637	<b>84.9</b>
<b>Sep.</b>	6,347	5,710	637	<b>84.9</b>
<b>Oct.</b>	6,347	5,710	637	<b>84.9</b>
<b>Nov.</b>	6,813	6,278	535	<b>71.3</b>
<b>Dec.</b>	8,603	7,869	734	<b>97.9</b>
<b>Jan. 2016</b>	8,603	7,869	734	<b>97.9</b>
<b>Feb.</b>	8,603	7,869	734	<b>97.9</b>
<b>Mar.</b>	8,603	7,869	734	<b>97.9</b>
<b>Apr.</b>	8,603	7,869	734	<b>97.9</b>
<b>May</b>	8,603	7,869	734	<b>97.9</b>
<b>Jun.</b>	8,603	7,869	734	<b>97.9</b>
<b>Jul.</b>	8,603	7,869	734	<b>97.9</b>
<b>Aug.</b>	8,603	7,869	734	<b>97.9</b>
<b>Sep.</b>	8,603	7,869	734	<b>97.9</b>
<b>Oct.</b>	8,603	7,869	734	<b>97.9</b>
<b>Nov.</b>	8,603	7,869	734	<b>97.9</b>
<b>Dec.</b>	8,490	7,891	600	<b>80.0</b>

# Field Operation Results

## ◆ OPI

- Off-peak days: 30 working days of Feb., Mar., and Jun. (2016)
- Peak days: 27 days of 2016



Period		LAB 1	LAB 2	LIB	Total
Feb. 2016 (Winter)	MES*	\$ 811	\$ 766	\$ 571	\$ 2,148
	AES**	\$ 783	\$ 732	\$ 553	\$ 2,068
	<b>OPI</b>	<b>96.6%</b>	<b>95.6%</b>	<b>96.8%</b>	<b>96.3%</b>
Mar. 2016 (Spring/Fall)	MES	\$ 350	\$ 312	\$ 179	\$ 841
	AES	\$ 341	\$ 307	\$ 170	\$ 818
	<b>OPI</b>	<b>97.6%</b>	<b>98.4%</b>	<b>94.7%</b>	<b>97.3%</b>
Jun. 2016 (Summer)	MES	\$ 998	\$ 882	\$ 497	\$ 2,337
	AES	\$ 996	\$ 874	\$ 470	\$ 2,340
	<b>OPI</b>	<b>99.8%</b>	<b>99.1%</b>	<b>94.5%</b>	<b>98.4%</b>
Peak days	MES	\$2,085	\$1,693	\$876	\$4,655
	AES	\$1,909	\$1,479	\$753	\$4,141
	<b>OPI</b>	<b>91.5%</b>	<b>87.4%</b>	<b>86.0%</b>	<b>89.0%</b>

\*MES: maximum energy charge saving with peak management

\*\*AES: actual energy charge saving

# Field Operation Results

## ◆ OPI vs Load forecast error



Overall, robust to load forecast uncertainty

# Field Operation Results

## ◆ Cost Saving in 2015

Month	Peak reduction [kW]			Peak charge saving [USD]	Energy charge saving [USD]			Total Saving [USD]
	before	after	peak-cut		LIB	LAB 1	LAB 2	
<b>1</b>	4,200	3,894	306	<b>2,465</b>	574	1,108	1,061	<b>5,209</b>
<b>2</b>	4,295	3,980	315	<b>2,551</b>	424	997	905	<b>4,858</b>
<b>3</b>	4,295	3,980	315	<b>2,551</b>	94	507	457	<b>3,591</b>
<b>4</b>	4,295	3,980	315	<b>2,551</b>	319	658	591	<b>4,101</b>
<b>5</b>	4,295	3,980	315	<b>2,551</b>	303	553	423	<b>3,813</b>
<b>6</b>	4,295	3,980	315	<b>2,551</b>	854	1,852	693	<b>5,932</b>
<b>7</b>	5,812	5,207	605	<b>4,870</b>	684	1,877	1,135	<b>8,566</b>
<b>8</b>	6,347	5,710	637	<b>5,126</b>	826	2,084	1,850	<b>9,886</b>
<b>9</b>	6,347	5,710	637	<b>5,126</b>	454	562	487	<b>6,629</b>
<b>10</b>	6,347	5,710	637	<b>5,126</b>	294	550	197	<b>6,167</b>
<b>11</b>	6,813	6,278	535	<b>4,308</b>	872	1,574	420	<b>7,174</b>
<b>12</b>	8,603	7,869	734	<b>5,909</b>	746	1,314	1,307	<b>9,277</b>
<b>Total</b>				<b>45,596</b>	6,444	13,636	9,525	<b>75,203</b>



# Field Operation Results

## ◆ Cost Saving in 2016

**Newly enforced!**

Month	Peak reduction [kW]			Peak charge saving [USD]	Energy charge saving [USD]			ESS Incentive [USD]		Total Saving [USD]
	before	after	peak-cut		LIB	LAB 1	LAB 2	charging discount	peak discount	
<b>1</b>	8,603	7,869	734	<b>5,910</b>	723	1,420	1,366	-	-	<b>9,419</b>
<b>2</b>	8,603	7,869	734	<b>5,910</b>	948	1,264	1,206	-	-	<b>9,328</b>
<b>3</b>	8,603	7,869	734	<b>5,910</b>	383	703	621	-	-	<b>7,617</b>
<b>4</b>	8,603	7,869	734	<b>5,910</b>	363	652	575	-	-	<b>7,500</b>
<b>5</b>	8,603	7,869	734	<b>5,910</b>	347	603	531	-	-	<b>7,391</b>
<b>6</b>	8,603	7,869	734	<b>5,910</b>	775	2,038	1,791	-	-	<b>10,514</b>
<b>7</b>	8,603	7,869	734	<b>5,910</b>	944	1,943	1,034	219	4,206	<b>14,255</b>
<b>8</b>	8,603	7,869	734	<b>5,910</b>	716	2,143	814	182	3,643	<b>13,407</b>
<b>9</b>	8,603	7,869	734	<b>5,910</b>	238	578	417	240	4,346	<b>11,729</b>
<b>10</b>	8,603	7,869	734	<b>5,910</b>	30	568	409	223	3,559	<b>10,698</b>
<b>11</b>	8,603	7,869	734	<b>5,910</b>	523	1,492	1,243	269	6,764	<b>16,200</b>
<b>12</b>	8,491	7,891	600	<b>4,829</b>	805	1,509	1,370	310	7,383	<b>16,205</b>
<b>Total</b>				<b>69,837</b>	6,795	14,913	11,376	1,443	29,901	<b>134,262</b>

# Field Operation Results

## ◆ Cost Saving in 2017

Month	Peak reduction [kW]			Peak charge saving [USD]	Energy charge saving [USD]			ESS Incentive [USD]		Total Saving [USD]
	before	after	peak-cut		LIB	LAB 1	LAB 2	charging discount	peak discount	
<b>1</b>	9,023	8,306	717	<b>5,774</b>	741	1,533	1,407	1,620	27,100	<b>38,174</b>
<b>2</b>	9,152	9,030	122	<b>981</b>	717	1,527	1,337	1,710	27,100	<b>33,372</b>
<b>3</b>	9,152	9,030	122	<b>981</b>	286	683	515	1,692	18,177	<b>22,334</b>
<b>Total</b>				<b>7,736</b>	1,744	3,743	3,259	5,022	72,377	<b>93,880</b>

- Big leap in cost saving from 2017 by the promotion incentive
- Sudden drop in peak reduction due to communication failure

# Field Operation Results

## ◆ Operation Characteristics (2014~2016)

Year	Lithium BESS				Lead-acid BESS 1				Lead-acid BESS 2			
	Char. [kWh]	Dischar. [kWh]	Eff. [%]	Cycle	Char. [kWh]	Dischar. [kWh]	Eff. [%]	Cycle	Char. [kWh]	Dischar. [kWh]	Eff. [%]	Cycle
<b>2014</b>	138,845	125,449	90.6	408	122,612	97,063	79.9	153	122,521	99,359	81.7	130
<b>2015</b>	148,209	133,296	89.8	435	335,197	268,910	80.3	314	258,100	205,261	79.5	242
<b>2016</b>	144,528	130,267	90.1	424	349,615	280,125	80.1	328	284,126	228,420	80.4	266
<b>Total</b>	431,582	389,012	<b>90.1</b>	1,267	807,424	646,098	<b>80.0</b>	795	664,747	533,040	<b>80.2</b>	638
<b>Monthly Average</b>	11,988	10,806	-	35.2	26,914	21,537	-	26.5	22,158	17,768	-	21.3

## ◆ Operation Performance

- Cost saving target (\$100K per year) reached in the 3<sup>rd</sup> year after 2 years of stabilization (in 2014 and 2015)
- 96 to 98% of ideal saving reached on off-peak days, 89% on peak-days, and 71 to 98% of ideal peak-cut in normal operation
- Two-level control scheme effective to handle uncertainty
- Overall reliability such as communication, electronic parts, etc. is crucial as well as control performance

# Observations

## ◆ Economic Evaluation

- Based on cost saving effect over the recent 1 year
- 15 year-operation scenario under promotion policy in place
- NPV(discount rate 5%), Bat. degradation, & Price change incl.

	With Incentive	Without Incentive
CAPEX		\$1,070K
OPEX		\$160K
Profit	\$1,189K	-\$167K
ROI	211%	84%
Payback	3.1 year	> 15 year

## ◆ Future Work

- State-of-health (SOH) Analysis
- Incorporation of Redox Flow Battery systems
- Upgrades on Optimal Operation Process



**Thank You !**

