



国家电网
STATE GRID

南瑞集团公司
NARI GROUP CORPORATION

Study on Calculation Method of Carbon Emission in Utilization of ACCC Conductor in New or Modified Power Lines

Xin Li

Nari Group



国家电网
STATE GRID

南瑞集团公司
NARI GROUP CORPORATION

Index



I

Characters and Advantages of ACCC

II

Description of Methodology

III

Case Analysis-Energy Saving

Characters and Advantages of ACCC



国家电网
STATE GRID



ACSR



ACCC



Compared with ACSR

- Higher tensile strength
- Lower CTE
- Greater ampacity
- Without Replacing Tower

Characters and Advantages of ACCC



国家电网
STATE GRID

A goal of Paris Climate 2015

2 °C compared to pre-industrial levels.

“Pursue efforts to” limit the temperature increase to 1.5 °C



南瑞集团公司(国网电力科学研究院)

NARI GROUP CORPORATION / STATE GRID ELECTRIC POWER RESEARCH INSTITUTE



国家电网
STATE GRID

南瑞集团公司
NARI GROUP CORPORATION

Index

I

Characters and Advantages of ACCC

II

Description of Methodology

III

Case Analysis-Energy Saving



Baseline emissions (BE_y)

$$BE_y = Q_{Line, BL, y} \times EF_{Elec, y} \quad (1)$$

BE_y——Baseline emissions in year y (tCO₂);

Q_{Line, BL, y}——The quantity of line loss at the baseline condition, as a result of the implementation of the CDM project activity, in year y, in accordance with monitoring data (MWh);

EF_{Elec, y}——CO₂ emission factor of the electric transmitted by grid in year y (tCO₂/MWh).

Line losses at baseline scenario ($Q_{Line, BL, y}$)

For single phase circuit

$$Q_{Line, BL, y} = n \frac{\sum_{i=1}^{m_y} (I_{PJ, i, y}^2)}{m_y} r_{BL} L_{BL} T_y / 10^6 \quad (2)$$

For three-phase lines

$$Q_{Line, BL, y} = 3n \frac{\sum_{i=1}^{m_y} (I_{PJ, i, y}^2)}{m_y} r_{BL} L_{BL} T_y / 10^6 \quad (3)$$

Project emissions (PE_y)

$$P_{Ey} = Q_{Line, PJ, y} \times EF_{Elec, y} \quad (4)$$

PE_y——Project emissions in year y (tCO₂);

Q_{Line, PJ, y}——The quantity of line loss at the project condition, as a result of the implementation of the CDM project activity, in year y, in accordance with monitoring data (MWh);

EF_{Elec, y}——CO₂ emission factor of the electric transmitted by grid in year y (tCO₂/MWh).

Line losses at project scenario (QLine, PJ, y)

For single phase circuit

$$Q_{Line,PJ,y} = n \frac{\sum_{i=1}^{m_y} (I_{PJ,i,y}^2)}{m_y} r_{PJ} L_{PJ} T_y / 10^6 \quad (5)$$

For three-phase lines

$$Q_{Line,PJ,y} = 3n \frac{\sum_{i=1}^{m_y} (I_{PJ,i,y}^2)}{m_y} r_{PJ} L_{PJ} T_y / 10^6 \quad (6)$$

Emission reductions (ER_y)

$$ER_y = BE_y - PE_y \quad (7)$$

ER_y —— Emission reductions in year y (tCO₂/y);

BE_y —— Baseline emissions in year y (tCO₂/y);

PE_y —— Project emissions in year y (tCO₂/y).



国家电网
STATE GRID

南瑞集团公司
NARI GROUP CORPORATION

Index

I

Characters and Advantages of ACCC

II

Description of Methodology

III

Case Analysis-Energy Saving



Transmission line technical parameters

Environmental Parameters:

Sunlight intensity=1026.9W/m²;

Environmental Temperature=30°C ;

Wind speed=0.6m/s;

Wind direction=90°.

Operating parameters:

Line length (L_{PJ}) =100 km;

Parallel number (n) =1;

Line running time (T_y)=8760 h;

CO₂ emission factor ($EF_{Elec, y}$) =0.8 tCO₂/MWh.

Case Analysis-Energy Saving



国家电网
STATE GRID

Item	Unit	Result			
		35	110	220	500
U	kV	35	110	220	500
ACSR Type	-	228-LGJ-120/20	369-LGJ-185/25	592-LGJ-300/40	789-LGJ-400/50
ACCC Type	-	291-148/20	471-239/24	745-378/44	1019-517/44
PE ₁	tCO ₂	57,294	63,308	141,074	300,529
BE ₁	tCO ₂	77,187	85,090	181,775	407,123
ER ₁	tCO ₂	19,893	21,782	40,701	106,594
Reduction ration	-	25.8%	25.6%	22.4%	26.2%

南瑞集团公司(国网电力科学研究院)

NARI GROUP CORPORATION / STATE GRID ELECTRIC POWER RESEARCH INSTITUTE



国家电网
STATE GRID

南瑞集团公司
NARI GROUP CORPORATION



Q & A